



| ITEM | CLASS "H" HOSPITAL TRANSFORMER DESCRIPTION | | | | QTY. |
|--------------------|--|---------|--------------------|-----------|------|
| | POWER | PRIMARY | VOLTAGE | SECONDARY | |
| 1 | 3 KVA | | 120 VOLTS | | 1 |
| | 5 KVA | | 208 VOLTS | | |
| | 7.5 KVA | | 240 VOLTS | | |
| | 10 KVA | | 277 VOLTS | | |
| | 15 KVA | | 480 VOLTS | | |
| 2 | LINE ISOLATION MONITOR: MICROPROCESSOR, 120 VOLT, TOTAL HAZARD INDEX TO BE (5) mA, 15 MICROAMPS LEAKAGE CURRENT, NON-SWITCHING 2 CHANNEL CIRCUITRY, AND ALARM FOR LOSS OF GROUND CONNECTION TO L.I.M., U.L. APPROVED TYPE COMPLETE WITH DIGITAL HAZARD CURRENT METER, GREEN AND RED INDICATOR LIGHTS, SILENCE AND TEST SWITCHES, BUZZER AND FUSES. | | | | 1 |
| 3 | CIRCUIT BREAKERS CONSISTING OF: | | 15 AMP | 2 POLE | |
| | | | 20 AMP | 2 POLE | |
| | | | 30 AMP | 2 POLE | |
| ** 16 CIRCUIT MAX. | | | | | |
| 4A | DUPLEX RECEPTACLE, 3 WIRE, 125V, 20A, HOSPITAL GRADE | | | | |
| 4B | SIMPLEX RECEPTACLE, 3 WIRE, 125V, 20A, HOSPITAL GRADE | | | | |
| 4C | TWIST LOCK RECEPTACLE, 3 WIRE, 125V, 20A, HOSPITAL GRADE | | | | |
| 5 | CLOCK - DIGITAL TYPE, 12 OR 24 HOUR | | | | |
| 6 | CLOCK CONTROL | | | | |
| 7 | TIMER - DIGITAL TYPE, 1 HOUR | | | | |
| 8 | TIMER CONTROL | | | | |
| 9 | GROUND JACK RECEPTACLE, TWIST TO LOCK, HAMPDEN 30amp | | | | |
| 10 | X-RAY VIEWER - DOUBLE, GENERAL PURPOSE TYPE | | | | 1 |
| 11 | X-RAY VIEWER ON/OFF SWITCH | | | | 1 |
| 12 | FM/AM STEREO CASSETTE PLAYER | | | | |
| | COMPACT DISK PLAYER & FM/AM STEREO COMPACT DISK, CASSETTE PLAYER, & FM/AM STEREO | | | | |
| 13 | SPEAKERS - 5 INCH WITH THIN GRILL | | | | |
| 14 | PRIMARY MAIN | | _____ AMPS, 2-POLE | | 1 |
| | CIRCUIT BREAKER | | _____ VOLTS | | |

- NOTES:
- 1) BOX WILL BE CONSTRUCTED OF GALVANIZED STEEL IN ACCORDANCE WITH U.L. STANDARD 50.
 - 2) FRONT DOOR AND ACCESSORY PLATES WILL BE MADE OF 12 GA., TYPE 304, STAINLESS STEEL, FINISHED WITH A #4 SATIN POLISH.
 - 3) REFERENCE DRAWING SB3169 WIRING DIAGRAM & INSTALLATION INSTRUCTIONS.
 - 4) MAXIMUM OF 8 RECEPTACLES.

FOR: **FOR REFERENCE ONLY**

STD. SFPSET.xls ACAD STD.: SB3168IV.dwg

POST GLOVER LIFELINK
4750 OLYMPIC BLVD. BLDG. B
ERLANGER, KY U.S.A. 41018 (859) 283-5900
COPYRIGHT © 2004

TITLE/DESCRIPTION:
SURGICAL FACILITY PANEL
16 CIRCUIT WITH PRIMARY MAIN, MARK IV
TYPE: SFP

DFTR: GCG DATE: 05/15/00 DWG. NO.: **SB3168IV** REV.: 02

ECN#04-016. UPDATED DRAWING.
JJM | 10/15/04 | 02
UPDATED VERTICAL WIRING BARRIERS.
JJM | 04/24/03 | 01
REVISIONS

S.O. NUM.:

THIS DOCUMENT AND THE INFORMATION IT CONTAINS ARE THE PROPERTY OF POST GLOVER LIFELINK. IT IS DISCLOSED FOR THE PURPOSE FOR WHICH IT IS FURNISHED AND SHALL NOT BE DUPLICATED OR DISTRIBUTED.