



ITEM	CLASS "H" HOSPITAL TRANSFORMER DESCRIPTION				QTY.			
1	POWER	PRIMARY	VOLTAGE	SECONDARY	1			
						10 KVA	110 VOLTS	
							120 VOLTS	
	208 VOLTS							
	15 KVA	220 VOLTS						
		240 VOLTS						
277 VOLTS								
480 VOLTS								
2	LINE ISOLATION MONITOR: MICROPROCESSOR, 120 VOLT, TOTAL HAZARD INDEX TO BE (5) mA, 15 MICROAMPS LEAKAGE CURRENT, NON-SWITCHING 2 CHANNEL CIRCUITRY, AND ALARM FOR LOSS OF GROUND CONNECTION TO L.I.M., U.L. APPROVED TYPE COMPLETE WITH DIGITAL HAZARD CURRENT METER, GREEN AND RED INDICATOR LIGHTS, SILENCE AND TEST SWITCHES, BUZZER AND FUSES.				1			
3	CIRCUIT BREAKERS CONSISTING OF:		15A 2-POLE					
	BOLT-ON,		20A 2-POLE					
	** 16 CIRCUIT MAX.		30A 2-POLE					
4	REMOTE ANNUNCIATOR TERMINAL BLOCK				1			
5	GROUND BUS-24 BRANCH CIRCUITS, SIZE #14 TO #6				1			
6	PRIMARY MAIN CIRCUIT BREAKER		_____ AMPS, 2-POLE		1			
			_____ VOLTS					
7	FRONT PANEL , 200-650-145				1			
8	BACKBOX, 200-650-214				1			

TOTAL REQUIRED _____

FOR REFERENCE ONLY

GENERAL NOTES:

- 1) BOX WILL BE CONSTRUCTED OF GALVANIZED STEEL, IN ACCORDANCE WITH U.L. STANDARD 50.
- 2) BOLT-IN CHASSIS FASTENS TO STUDS IN BACK OF BOX.
- 3) FRONT WILL BE FABRICATED OF 12GA., TYPE 304 STAINLESS STEEL AND FINISHED WITH A #4 SATIN POLISH.
- 4) CONDUIT ENTRANCE AREA IS DESIGNED ON LAYOUT FOR GROUNDED POWER ONLY. BRANCH CIRCUITS AND SIGNAL CONDUITS MAY ENTER ANY OTHER AREA OF BOX.
- 5) BRANCH CIRCUIT WIRING TO BE #12 XHHW.

REFERENCE:

FOR:

STD. B.O.M.: IDP10-15.xls

ACAD STD.: SB3201IV.dwg



POST GLOVER LIFELINK
 4750 OLYMPIC BLVD. BLDG. B
 ERLANGER, KY U.S.A. 41018 (859) 283-5900
 COPYRIGHT © 2004

TITLE/DESCRIPTION:
 10 & 15KVA ISOLATED DISTRIBUTION PANEL
 FLUSH MOUNT, 16 CIRCUIT MAX., MARK IV
 TYPE: IDP

DFTR: GCG DATE: 02/21/00 DWG. NO.: REV.: 01

ECN# 04-016. UPDATED DRAWING.
 JJM | 04/21/04 | 01

REVISIONS
 S.O. NUM.:

THIS DOCUMENT AND THE INFORMATION IT CONTAINS ARE THE PROPERTY OF POST GLOVER LIFELINK. IT IS DISCLOSED FOR THE PURPOSE FOR WHICH IT IS FURNISHED AND SHALL NOT BE DUPLICATED OR DISTRIBUTED.